

ADDENDUM #3

INVITATION TO BID #10-195

SKID MOUNTED RECLAIMED WATER BOOSTER PUMPING STATION

March 9, 2010

Upgrade Booster Pump Control Panel Service Feed from 100AMP to 125AMP per the attached partial sketches of drawings E-01, E-02 and E-04.

End.